

HIMACHAL PRADESH  
PUBLIC WORKS DEPARTMENT

Telephone No: - 01905-243262

E-mail: - [eepwd-nerchowk-hp@gov.in](mailto:eepwd-nerchowk-hp@gov.in)

No.PW-NCD / WA-Building Safety/2023-24:- 5759-60

Dated:- 30/8/23

To

The Principal,  
DAV Public School  
Nerchowk (Dadour)  
Tehsil Balh Distt. Mandi (HP)


Subject:-

Regarding Building Safety Certificate.


In this connection it is intimated that the building namely DAV Public School Nerchowk (Dadour) Tehsil Balh Distt. Mandi (HP) inspected by the Assistant Engineer Chakkar Sub Division HP,PWD Nerchowk and seen that this is a four storey building on RCC column with brick work. The department neither supervised above building during construction at any stage nor foundation depth, quality of material used & cement concrete ratio used known/ checked. Moreover, no detailed structural analysis and drawings in seismic and non-seismic conditions are available to check the safety of building. However, as per submitted architectural drawing or on visual inspection, the building seems to be safe in normal condition to run the college/Institute for the academic year 2023-24 with the following terms and conditions:-

1. This certificate stands to be cancelled if any additional/alteration to College/Institute Building as per the architectural drawing submitted as above are made or any other load is increased on building.
2. This department holds no responsibility regarding safety during natural calamity i.e. earthquake, cloud burst, floods, unequal settlement etc.
3. The maintenance of the building is to be carried out properly.

Encl:-As above.

  
Executive Engineer,  
HP.PWD., Division,  
Nerchowk.

Copy to the Assistant Engineer Chakkar Sub-Division HP.PWD., Nerchowk with reference to his office letter No. 1140-41 dated 07-08-2023 for information.

  
Executive Engineer,  
HP.PWD., Division,  
Nerchowk.